

# 檢測報告

東典環安科技股份有限公司

行政院環境保護署許可字號：環署環檢字第093號

專案編號：HW1090D0498 報告編號：D10906100003001

報告日期：109年12月17日 行程編號：HWDW201203A24

[受測單位]

法務部矯正署宜蘭監獄

行業別：\*

檢測目的：定期檢測

採樣單位：東典環安科技股份有限公司環檢中心

採樣地址：宜蘭縣三星鄉三星路3段365巷安農新村1號

樣品名稱：大炊場

採樣日期：109/12/03 08:28

樣品編號：D1091203-5-1

收樣日期：109/12/03 16:26

檢測項目	檢測值 單位	檢測方法		備註
		是否經認可	量測值/MDL(QDL)/類別	
大腸桿菌群	<1 CFU/100mL	* NIEA E230.55B	飲用水	
自由有效餘氯	0.42 mg/L	* NIEA W408.51A	飲用水	
總菌落數 (有消毒系統之水廠配水管網)	51 CFU/mL	* NIEA E204.55B	飲用水	

樣品名稱：1號井

採樣日期：109/12/03 08:43

樣品編號：D1091203-5-2

收樣日期：109/12/03 16:26

檢測項目	檢測值 單位	檢測方法		備註
		是否經認可	量測值/MDL(QDL)/類別	
硝酸鹽氮	1.19 mg/L	* NIEA W419.51A	飲用水	
砷	N. D. mg/L	* NIEA W434.54B	MDL=0.00015/飲用水	

樣品名稱：2號井

採樣日期：109/12/03 08:45

樣品編號：D1091203-5-3

收樣日期：109/12/03 16:26

檢測項目	檢測值 單位	檢測方法		備註
		是否經認可	量測值/MDL(QDL)/類別	
硝酸鹽氮	1.09 mg/L	* NIEA W419.51A	飲用水	
砷	N. D. mg/L	* NIEA W434.54B	MDL=0.00015/飲用水	

樣品名稱：3號井


採樣日期：109/12/03 08:47

樣品編號：D1091203-5-4

收樣日期：109/12/03 16:26

檢測項目	檢測值 單位	檢測方法		備註
		是否經認可	量測值/MDL(QDL)/類別	
硝酸鹽氮	1.09 mg/L	* NIEA W419.51A	飲用水	
砷	N. D. mg/L	* NIEA W434.54B	MDL=0.00015/飲用水	

-----以下空白-----



## REPORT OF DRINKING WATER ANALYSIS

EPA Accredited Lab ID # : NO.093

Sampling Company : East Tender Environmental and Safety Technology CO.,LTD.

Laboratory Add. : No.99, Ligong 2nd Rd., Wujie Township, Yilan County 268, Taiwan (R.O.C.)

Sampling Add. : No. An Nong Xincun 1, Ln. 365, Sec. 3, Sanxing Rd., Sanxing Township, Yilan County 266, Taiwan (R.O.C.)

TEL : (03)9900999

Purpose : For Testing

FAX : (03)9900998

Sample Collection Date : 2020/12/3 08:38

Name of Applicant : Yilan Prison, Agency of Corrections, Ministry of Justice

Lab Receipt Date : 2020/12/3 16:26

Report Completed Date : 2020/12/17

Industry Classifications : \*

Items	Unit	Lab Sample No.	Result Value		Analysis Method	Remarks
		D1091203-5-1				
Coliform group	CFU/100mL	Dakanchang	<1		NIEA E230.55B	
Free available residual chlorine	mg/L		0.42		NIEA W408.51A	
Colony forming	CFU/mL		51		NIEA E204.55B	
Blank below						

Announcement :


All the above items are analyzed by credit EPA laboratory. I certify that information submitted is, to the best of my knowledge and belief, true, accurate, and complete.

Company : East Tender Environmental and Safety Technology CO.,LTD.

President of ETEST : Zheng-Liang Lin

Authorized signature :

陳西元代





## REPORT OF DRINKING WATER ANALYSIS

EPA Accredited Lab ID # : NO.093

Sampling Company : East Tender Environmental and Safety Technology CO.,LTD.

Laboratory Add. : No.99, Ligong 2nd Rd., Wujie Township, Yilan County 268, Taiwan (R.O.C.)

Sampling Add. : No. An Nong Xincun 1, Ln. 365, Sec. 3, Sanxing Rd., Sanxing Township, Yilan County 266, Taiwan (R.O.C.)

TEL : (03)9900999

Purpose : For Testing

FAX : (03)9900998

Sample Collection Date : 2020/12/3 08:43

Name of Applicant : Yilan Prison, Agency of Corrections, Ministry of Justice

Lab Receipt Date : 2020/12/3 16:26

Report Completed Date : 2020/12/17

Industry Classifications : \*

Items	Unit	Lab Sample No.	Result Value		Analysis Method	Remarks
		D1091203-5-2	Well 1			
NO <sub>3</sub> -N	mg/L		1.19		NIEA W419.51A	
As	mg/L		N.D.		NIEA W434.54B	MDL=0.00015
Blank below						

**Announcement :**


All the above items are analyzed by credit EPA laboratory. I certify that information submitted is, to the best of my knowledge and belief, true, accurate, and complete.

Company : East Tender Environmental and Safety Technology CO.,LTD.

President of ETEST : Zheng-Liang Lin

Authorized signature :

陳西元代



## REPORT OF DRINKING WATER ANALYSIS

EPA Accredited Lab ID # : NO.093

Sampling Company : East Tender Environmental and Safety Technology CO.,LTD.

Laboratory Add. : No.99, Ligong 2nd Rd., Wujie Township, Yilan County 268, Taiwan (R.O.C.)

Sampling Add. : No. An Nong Xincun 1, Ln. 365, Sec. 3, Sanxing Rd., Sanxing Township, Yilan County 266, Taiwan (R.O.C.)

TEL : (03)9900999

Purpose : For Testing

FAX : (03)9900998

Sample Collection Date : 2020/12/3 08:45

Name of Applicant : Yilan Prison, Agency of Corrections, Ministry of Justice

Lab Receipt Date : 2020/12/3 16:26

Report Completed Date : 2020/12/17

Industry Classifications : \*

Items	Unit	Lab Sample No.	Result Value		Analysis Method	Remarks
		D1091203-5-3 Well 2				
NO <sub>3</sub> -N	mg/L	1.09			NIEA W419.51A	
As	mg/L	N.D.			NIEA W434.54B	MDL=0.00015
Blank below						

## Announcement :


All the above items are analyzed by credit EPA laboratory. I certify that information submitted is, to the best of my knowledge and belief, true, accurate, and complete.

Company : East Tender Environmental and Safety Technology CO.,LTD.

President of ETEST : Zheng-Liang Lin

Authorized signature :

陳西元代



## REPORT OF DRINKING WATER ANALYSIS

EPA Accredited Lab ID # : NO.093	Sampling Company : East Tender Environmental and Safety Technology CO.,LTD.
Laboratory Add. : No.99, Ligong 2nd Rd., Wujie Township, Yilan County 268, Taiwan (R.O.C.)	Sampling Add. : No. An Nong Xincun 1, Ln. 365, Sec. 3, Sanxing Rd., Sanxing Township, Yilan County 266, Taiwan (R.O.C.)
TEL : (03)9900999	Purpose : For Testing
FAX : (03)9900998	Sample Collection Date : 2020/12/3 08:47
Name of Applicant : Yilan Prison, Agency of Corrections, Ministry of Justice	Lab Receipt Date : 2020/12/3 16:26
	Report Completed Date : 2020/12/17

Industry Classifications : \*

Items	Unit	Lab Sample No.		Result Value	Analysis Method	Remarks
		D1091203-5-4	Well 3			
NO <sub>3</sub> -N	mg/L		1.09		NIEA W419.51A	
As	mg/L		N.D.		NIEA W434.54B	MDL=0.00015
Blank below						

Announcement :

All the above items are analyzed by credit EPA laboratory. I certify that information submitted is, to the best of my knowledge and belief, true, accurate, and complete.

Company : East Tender Environmental and Safety Technology CO.,LTD.

President of ETEST : Zheng-Liang Lin

Authorized signature :

報告專用章

東典環安科技(股)公司

負責人:林正亮

檢驗室主管:許智明